



Athens-Clarke County Fire & Emergency Services



1.1.3 IFC Appendix D Acknowledgement & IFC 510 Compliance Acknowledgement

Before a Fire Safety Codes Release or Certificate of Occupancy is issued, compliance with International Fire Code Appendix D is required. Additionally, when applicable, International Fire Code Section 510 is required by means of an Emergency Responder Radio Coverage System (ERRCS) installed, tested, and accepted or through field testing by an FCC-licensed radio contractor to verify that an EDRRCS is not warranted. A critical element to compliance with this standard is preliminary testing once the building is dried-in.

Applicant will acknowledge and agree to the above requirements during their Construction Plans Review Application submittal.

700 College Avenue
Athens, Georgia 30601
(706) 613-3364

www.athensclarkecounty.com

Honesty

Dependability

Teamwork

Professionalism

Camaraderie