



Athens-Clarke County  
PUBLIC UTILITIES DEPARTMENT  
Cross Connections  
Plans Review Checklist



Plans Review Checklist	OK	Completed
1. Fire Sprinkler services shall have a Double Check Detector Check Assembly.		
2. Non-Hazard domestic services shall have a Double Check Assembly		
3. High Hazard domestic services shall have a Reduced Pressure Zone Assembly.		
4. Utility plans showing BFP type and locations outside of the ROW or easement.		
5. BFP's shall be installed 3 to 6 feet from point of connection. Any installations beyond this will need prior approval by the Cross Connection Coordinator.		
6. BFP's shall not be installed no higher than 3 feet from the floor and none shall be installed in a ceiling.		
7. Detail sheet showing the approved installation requirements.		
8. Existing easements and proposed easements.		
9. Overall utility plan w/ grid north arrow.		
10. Existing utilities w/ elevation if applicable (fire hydrants, meters, manhole tops & inverts).		
11. Property lines w/ adjacent owners names.		
12. Existing and proposed right of way (if applicable).		

**\*The above is not an all-inclusive list but was created to help guide an applicant through the Plans Review process. Project specific details may vary.\***