

**ATHENS-CLARKE COUNTY  
J.G BEACHAM WATER TREATMENT PLANT  
800 WATERWORKS DRIVE  
ATHENS, GEORGIA 30601  
PHONE: (706) 613-3481 FAX: (706) 613-3477**

**ROUTINE TAP WATER ANALYSIS**

**QUARTER: SECOND QUARTER**

<b>LABORATORY I.D. NUMBER :</b>	<u>001</u>	<b>SAMPLE SITE :</b>	<u>OPERATOR'S LABORATORY</u>
<b>REPORT NUMBER :</b>	<u>5/12/2025-01</u>	<b>DATE SAMPLED :</b>	<u>5/12/2025</u>
<b>ANALYZED BY :</b>	<u>Y. Chapman</u>	<b>DATE RECEIVED :</b>	<u>5/12/2025</u>
<b>COLLECTED BY :</b>	<u>Y. Chapman</u>	<b>DATE REPORTED :</b>	<u>5/14/2025</u>

---

**THE WATER WAS ANALYZED ACCORDING TO "STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER" LATEST EDITION, APHA, AWWA, AND WPCF.**

---

**RESULTS**

**RESULTS EXPRESSED IN MG/L UNLESS INDICATED OTHERWISE**

<b>pH</b>	<u>7.36 SU</u>	<b>ORTHOPHOSPHATE</b>	<u>0.22</u>
<b>ALKALINITY</b>	<u>26</u>	<b>HETEROTROPIC PLATE COUNT</b>	<u>0 CFU's</u>
<b>CONDUCTIVITY</b>	<u>72.9 <math>\mu</math>s/cm</u>	<b>CHLORINE</b>	<u>1.23</u>
<b>TOTAL DISSOLVED SOLIDS</b>	<u>36.5</u>	<b>POTASSIUM</b>	<u>2.6</u>
<b>ALUMINUM</b>	<u>0.008</u>	<b>TONS</b>	<u>0</u>
<b>TOTAL HARDNESS</b>	<u>31</u>	<b>FLUORIDE</b>	<u>0.62</u>
<b>NITROGEN NITRATE</b>	<u>2.0</u>	<b>CALCIUM</b>	<u>8.8</u>
<b>NITROGEN AMMONIA</b>	<u>0</u>	<b>CALCIUM HARDNESS</b>	<u>22</u>
<b>COLIFORM BACTERIA</b>	<u>Negative</u>	<b>MAGNESIUM</b>	<u>2.2</u>
<b>TEMPERATURE</b>	<u>20.3°C</u>	<b>pHS</b>	<u>9.42</u>
<b>CARBON DIOXIDE</b>	<u>3.00</u>	<b>LANGEIER INDEX</b>	<u>-2.06</u>
<b>MANGANESE</b>	<u>0.002</u>	<b>IRON</b>	<u>0.01</u>
<b>ZINC</b>	<u>0</u>	<b>SODIUM</b>	<u>30.82</u>
<b>CHLORIDE</b>	<u>10.0</u>	<b>HYDROGEN SULFIDE</b>	<u>0</u>
<b>TURBIDITY</b>	<u>0.07 NTU's</u>	<b>SULFATE</b>	<u>14</u>