

**ATHENS-CLARKE COUNTY
J.G BEACHAM WATER TREATMENT PLANT
800 WATERWORKS DRIVE
ATHENS, GEORGIA 30601
PHONE: (706) 613-3481 FAX: (706) 613-3477**

ROUTINE TAP WATER ANALYSIS

QUARTER: SECOND QUARTER

LABORATORY I.D. NUMBER :	<u>001</u>	SAMPLE SITE :	<u>OPERATOR'S LABORATORY</u>
REPORT NUMBER :	<u>04/07/2020-02</u>	DATE SAMPLED :	<u>4/7/2020</u>
ANALYZED BY :	<u>B. Wilson</u>	DATE RECEIVED :	<u>4/7/2020</u>
COLLECTED BY :	<u>B. Wilson</u>	DATE REPORTED :	<u>4/9/2020</u>

THE WATER WAS ANALYZED ACCORDING TO "STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER" LATEST EDITION, APHA, AWWA, AND WPCF.

RESULTS

RESULTS EXPRESSED IN MG/L UNLESS INDICATED OTHERWISE

pH	<u>7.37 SU</u>	TOTAL PHOSPHATE	<u>0.81</u>
ALKALINITY	<u>25</u>	HETEROTROPIC PLATE COUNT	<u>0 CFU's</u>
CONDUCTIVITY	<u>108.3 μs/cm</u>	CHLORINE	<u>1.45</u>
TOTAL DISSOLVED SOLIDS	<u>54.1</u>	POTASSIUM	<u>1.7</u>
ALUMINUM	<u>0.031</u>	TONS	<u>0</u>
TOTAL HARDNESS	<u>34</u>	FLUORIDE	<u>0.73</u>
NITROGEN NITRATE	<u>1.7</u>	CALCIUM	<u>9.6</u>
NITROGEN AMMONIA	<u>0</u>	CALCIUM HARDNESS	<u>24</u>
COLIFORM BACTERIA	<u>0</u>	MAGNESIUM	<u>2.44</u>
TEMPERATURE	<u>19.0°C</u>	pHS	<u>9.39</u>
CARBON DIOXIDE	<u>3.5</u>	LANGEIER INDEX	<u>-2.02</u>
MANGANESE	<u>0</u>	IRON	<u>0.02</u>
ZINC	<u>0.04</u>	SODIUM	<u>0</u>
CHLORIDE	<u>10.0</u>	HYDROGEN SULFIDE	<u>0</u>
TURBIDITY	<u>0.12 NTU's</u>	SULFATE	<u>2.0</u>