


UNDER RAILROADS

PIPE DIAMETER	CASING DIAMETER	MIN. WALL THICKNESS
8"	18"	.313"
10"	20"	.344"
12"	22"	.375"
14"	24"	.407"
16"	30"	.469"



UNDER HIGHWAYS

PIPE DIAMETER	CASING DIAMETER	MIN. WALL THICKNESS
8"	16"	.250"
10"	16"	.250"
12"	18"	.250"
16"	24"	.250"
20"	30"	.312"
30"	42"	.375"

- NOTE:**
1. CASING TO EXTEND 4' BEYOND CURB & GUTTER OR EDGE OF PAVEMENT IN FILL SECTION.
 2. CASING TO EXTEND 2' BEYOND THE BACK EDGE OF THE BOTTOM OF THE DITCH OR 2' BEYOND THE BOTTOM OF A V-DITCH.
 3. FOR WATER AND/OR SANITARY SEWER ONLY.

Casing and Spacer Detail

NTS

G-3

Standard Specification and Detail for:
Casing and Spacer Detail

GMD: NA	County: Athens-Clarke	State: Georgia	Date: August, 2019
Drawn by: <i>KFM</i>		The Unified Government of Athens-Clarke County Department of Public Utilities 124 E Hancock Ave Athens, Georgia 30601 Fax: 706-613-3198 Voice: 706-613-3490	
Approved by: <i>GJ</i>			
Scale: AS-SHOWN			

