


FOR TRAFFIC AREA, USE STANDARD  
C.I. RING AND COVER EQUAL TO  
VULCAN 1480-1 OR  
U.S. FOUNDRY 362.

MANHOLE RING TO BE  
GROUTED IN PLACE.

MANHOLE COVER SHOULD  
READ "SAMPLE STATION".

FOR NON-TRAFFIC AREA, USE LIGHT  
DUTY C.I. RING AND COVER WITH 4"  
DROP HANDLE EQUAL TO U.S.  
FOUNDRY 360-K.



## Industrial Sample Manhole NTS

MH-13

Standard Specification and Detail for:

### Industrial Sample Manhole

GMD: NA

County: Athens-Clarke

State: Georgia

Date: August, 2019

Drawn by: KFM

The Unified Government of Athens-Clarke County

Department of Public Utilities

124 E Hancock Ave

Athens, Georgia 30601

Voice: 706-613-3490

Approved by: GJ

Scale: AS-SHOWN

Fax: 706-613-3198

