



NOTES:

1. 18" TO 24" SCREW ADJUSTABLE
2. 6" SCHEDULE 40 PVC FOR EXTENSION

Gate Valve Detail

NTS

W-8

Standard Specification and Detail for:

Gate Valve

GMD: NA	County: Athens-Clarke	State: Georgia	Date: August, 2019
---------	-----------------------	----------------	--------------------

Drawn by: *KFM*

Approved by: *GJ*

Scale: *AS-SHOWN*

The Unified Government of Athens-Clarke County
Department of Public Utilities

124 E Hancock Ave
Athens, Georgia 30601

Fax: 706-613-3198

Voice: 706-613-3490

