

NOTE:

1. BACKFLOW DEVICES AND VAULTS PER ACC BACKFLOW PROGRAM.
2. ALL APPLICABLE NFPA REQUIREMENTS APPLY.
3. NO PIV'S ON PUBLIC WATER MAINS.
4. WHERE RIGHT OF WAY IS NOT SUFFICIENT, 20' EASEMENT IS REQUIRED.

## Fire and Service Detail

NTS

W-10

Standard Specification and Detail for:

### Fire and Domestic Service Detail

GMD: NA County: Athens-Clarke State: Georgia Date: June, 2025

Drawn by: KFM

Approved by: MRA

Scale: AS-SHOWN

The Unified Government of Athens-Clarke County  
**Department of Public Utilities**124 E Hancock Ave  
Athens, Georgia 30601

Voice: 706-613-3490

