



NOTE:

1. BACKFLOW DEVICES AND VAULTS PER ACC BACKFLOW PROGRAM.
2. ALL APPLICABLE NFPA REQUIREMENTS APPLY.
3. NO PIV'S ON PUBLIC WATER MAINS.
4. WHERE RIGHT OF WAY IS NOT SUFFICIENT, 20' EASEMENT IS REQUIRED.

Fire and Service Detail

NTS

W-10

Standard Specification and Detail for:

Fire and Domestic Service Detail

GMD: NA	County: Athens-Clarke	State: Georgia	Date: August, 2019
Drawn by: KFM		The Unified Government of Athens-Clarke County Department of Public Utilities 124 E Hancock Ave Athens, Georgia 30601	
Approved by: GJ			
Scale: AS-SHOWN			
Fax: 706-613-3198		Voice: 706-613-3490	

