



NOTE:

1. BACKFLOW DEVICES AND VAULTS PER ACC BACKFLOW PROGRAM.
2. ALL APPLICABLE NFPA REQUIREMENTS APPLY.
3. NO PIV'S ON PUBLIC WATER MAINS.
4. WHERE RIGHT OR WAY IS NOT SUFFICIENT, 20' EASEMENT IS REQUIRED.
5. CONTRACTOR TO PROVIDE WATER SERVICES WHEN INSTALLATION OCCURS AS PART OF A WATER MAIN EXTENSION.

Fire, Domestic & Irrigation Service Detail

NTS

W-12

Standard Specification and Detail for:

Fire, Domestic and Irrigation Service Detail

GMD: NA	County: Athens-Clarke	State: Georgia	Date: August, 2019
Drawn by: KFM		The Unified Government of Athens-Clarke County Department of Public Utilities 124 E Hancock Ave Athens, Georgia 30601 Fax: 706-613-3198 Voice: 706-613-3490	
Approved by: GJ			
Scale: AS-SHOWN			

