



NOTE: 1 IF TRENCH IS IN ROCK TYPE 4 BEDDING IS REQUIRED

NOTE: 12" DIP AND LARGER THAT IS DEEPER THAN 15' SHALL HAVE STONE UP TO SPRING LINE.

Water Pipe Bedding Detail

NTS

W-14

Standard Specification and Detail for:

Water Pipe Bedding Detail

GMD: NA	County: Athens-Clarke	State: Georgia	Date: August, 2019
Drawn by: KFM		The Unified Government of Athens-Clarke County Department of Public Utilities 124 E Hancock Ave Athens, Georgia 30601 Fax: 706-613-3198 Voice: 706-613-3490	
Approved by: GJ			
Scale: AS-SHOWN			

