



NOTE: FOR TRENCHES IN ROCK MINIMUM TRENCH WIDTH IS 3'-0" AND MINIMUM BEDDING IS 6".

*TYPE 3 MODIFIED (ACC 1990)

NOTE: 12" DIP DEEPER THAN 15' SHALL HAVE STONE UP TO SPRING LINE.

*TYPE 3 MODIFIED (ACC 1990)
*TYPE 4 MODIFIED DIPRA

NOTE: IF THE TRENCH IS EXCAVATED TO EXCESSIVE WIDTH, BEDDING AND HAUNCHING WITH NO.57 CRUSHED STONE IS REQUIRED TO 12 INCHES ABOVE THE TOP OF PIPE (PVC) AND TO THE CROWN (DIP)

*PLUS ANY UNDERCUT

Sanitary Sewer Bedding Detail

NTS

SS-7

Standard Specification and Detail for:

Sanitary Sewer Pipe Bedding Detail

GMD: NA	County: Athens-Clarke	State: Georgia	Date: August, 2019
Drawn by: KFM	The Unified Government of Athens-Clarke County Department of Public Utilities 124 E Hancock Ave Athens, Georgia 30601 Fax: 706-613-3198 Voice: 706-613-3490		
Approved by: GJ			
Scale: AS-SHOWN			

